

BY ELECTRONIC MAIL

May 20, 2016

Ms. Susan Mackert
Department of Environmental Quality
Northern Regional Office
13901 Crown Court
Woodbridge, VA 22193

**RE: Dominion Possum Point Power Station VA0002071
Outfall 503 Weekly Discharge Monitoring and Site Activity Report**

Ms. Mackert:

Dominion is submitting this letter in accordance with Part I.A.4.(5) of the subject permit. Results of discharge sampling for Outfall 503 conducted during the week of May 8 – 14, 2016 are included on the enclosed Weekly Compliance Sampling Summary. In addition, a progress report summarizing the status of activities to the CCR Surface Impoundment Closure Project is attached with this report.

If you have any questions or need additional information, please contact Jeff Marcell at (703)-441-3813.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,



Jeffrey R. Marcell
Environmental Supervisor

WEEKLY COMPLIANCE SAMPLING SUMMARY

Facility Name:
POSSUM POINT POWER STATION
Permit Number:
VA0002071
Outfall Number:
503

Sample Week:
5/8/16 - 5/14/16
Report Due Date:
5/20/2016

Parameter	Units	Frequency	Permit QL	Analytical Report Date		Result	Result
				Daily	Maximum Limitation		
Flow	MGD	Weekly	NA	2.88	0.432	0.537	0.483
pH*	S.U.	Weekly	NA	8.01	7.74	7.98	
Total Suspended Solids	mg/L	Weekly	1.0	100	< QL	< QL	
Oil & Grease	mg/L	Weekly	NA	20	< 5.0	< 5.0	
Antimony, Total Recoverable	ug/L	Weekly	5.0	1300	< QL	< QL	
Arsenic, Total Recoverable	ug/L	Weekly	5.0	440	< QL	< QL	
Cadmium, Total Recoverable	ug/L	Weekly	0.88	2.6	< QL	< QL	
Chromium III, Total Recoverable	ug/L	Weekly	5.0	160	< QL	< QL	
Chromium VI, Total Recoverable	ug/L	Weekly	5.0	32	< QL	< QL	
Copper, Total Recoverable	ug/L	Weekly	5.0	18	< QL	< QL	
Lead, Total Recoverable	ug/L	Weekly	5.0	26	< QL	< QL	
Mercury, Total Recoverable	ug/L	Weekly	0.1	2.2	< QL	< QL	
Nickel, Total Recoverable	ug/L	Weekly	5.0	44	< QL	< QL	
Selenium, Total Recoverable	ug/L	Weekly	5.0	15	< QL	< QL	
Silver, Total Recoverable	ug/L	Weekly	0.4	4.0	< QL	< QL	
Thallium, Total Recoverable	ug/L	Weekly	0.47	0.94	< QL	< QL	
Zinc, Total Recoverable	ug/L	Weekly	25	180	< QL	< QL	
Chloride	ug/L	Weekly	NA	670,000	81,100	76,200	96,500
Hardness, Total (as CaCO ₃)	mg/L	Weekly	NA	NL	102	143	166

Notes:

*pH values must remain between a minimum of 6.0 S.U. and a maximum of 9.0 S.U. at all times. pH values are measured in the field
 Analytical results below the Permit Quantification level (QL) are to be reported as "<QL", as required in Section I.C.2 of the Permit
 QL = Quantification Level
 NA = Not Applicable
 NL = No Limitation, monitoring required

¹ A contract is in place to receive results for parameters identified in the VPDES permit with a monitoring frequency of "3/W" within four business days of taking the sample. The original analytical report for this sampling event was received on 5/12/2016. Due to a data qualifier, the sample was reanalyzed and a revised report was provided on 5/16/2016.

² A contract is in place to receive results for parameters identified in the VPDES permit with a monitoring frequency of "3/W" within four business days of taking the sample. The original analytical report for this sampling event was received on 5/17/2016. Due to a data qualifier, the sample was reanalyzed and a revised report was provided on 5/19/2016.

Dominion – Possum Point Power Station

CCR Impoundment Closure Project

Weekly Status Report

Activities for the Week Ending: 5/14/16

- Initiated Wastewater Treatment System operation
- Approximately 2.5 MG of Wastewater Treatment System treated water was discharged via outfall 503.

Ongoing Activities

- Pumping of filtered water from Ponds A, B, C and E to Pond D.
- Stock piling of dry ash from Pond E within the pond footprint to facilitate future loading operations.

Look Ahead

- See ongoing activities.